


NOTES:

- 1. LOCATE STRUCTURE ADJACENT TO DRIVE AND FOR ACCESS BY MAINTENANCE VEHICLE.
- 2. FILL WITH CLEAN WATER PRIOR TO START UP OF SYSTEM.
- 3. INTERCEPTOR TO BE MAINTAINED BY OWNER AND ANNUAL MAINTENANCE REPORT WILL BE REQUIRED.
- 4. UTILITY VAULT CO., INC. MODEL NO. 5106 GA OR EQUAL.
- 5. CONNECTIONS TO CONCRETE WALLS WITH PVC PIPE REQUIRES KOR-N-SEAL CONNECTOR OR A.C. X PVC BRANT ADAPTER OR APPROVED EQUAL. SEAL ALL PIPE CONNECTIONS WITH NON-SHRINK GROUT.
- 6. 6" PVC SHALL BE USED THROUGHOUT. PIPE MATERIAL SHALL BE PER STANDARDS. TOP OF "TEES" TO BE KEPT OPEN.

- GRAY WATER ONLY. BLACK WATER SHALL BE CARRIED BY SEPARATE SIDE SEWER.
- 8. ANY CHANGES REQUIRE PRIOR APPROVAL BY THE ENGINEER

NOTE: THIS PLAN IS NOT A LEGAL ENGINEERING DOCUMENT BUT AN ELECTRONIC DUPLICATE. THE ORIGINAL, SIGNED BY THE ENGINEER AND APPROVED FOR PUBLICATION IS KEPT ON FILE AT THE CITY OF KENT. A COPY MAY BE OBTAINED UPON REQUEST.



CITY OF KENT ENGINEERING DEPARTMENT

1,500 GALLON GREASE INTERCEPTOR

 DESIGNED
 DMW
 SCALE
 NONE
 STANDARD PLAN

 DRAWN
 BB
 DATE
 4-11

 APPROVED
 ENGINEER