



NOTES:

1. JOINT DEFLECTION SHALL NOT BE GREATER THAN RECOMMENDED BY THE PIPE MANUFACTURER AND APPROVED BY THE ENGINEER.
2. MINIMUM SLOPE SHALL BE 1%. MAX. PERMISSIBLE SLOPE SHALL BE 2 HORIZ. TO 1 VERT. UNLESS SPECIFIED OTHERWISE.
3. PIPE SHALL BE PVC, CAST IRON, OR DUCTILE IRON CLASS 50, MIN. SIZE 6". SIZE AND MATERIAL SHALL BE AS SPECIFIED ON THE PLANS OR APPROVED BY THE ENGINEER.
4. 5' MINIMUM SEPARATION BETWEEN SEWER MAIN TAPS.
5. STUBS SHALL EXTEND 2' BEYOND ANY DRY UTILITY EASEMENTS.



NOTE: THIS PLAN IS NOT A LEGAL ENGINEERING DOCUMENT BUT AN ELECTRONIC DUPLICATE. THE ORIGINAL, SIGNED BY THE ENGINEER AND APPROVED FOR PUBLICATION IS KEPT ON FILE AT THE CITY OF KENT. A COPY MAY BE OBTAINED UPON REQUEST.

		CITY OF KENT ENGINEERING DEPARTMENT	
		SIDE SEWER STUB CONNECTION	
DESIGNED	COK	SCALE	NONE
DRAWN	COK	DATE	12/2019
CHECKED	COK	ENGINEER	
APPROVED			
			STANDARD PLAN 4-8