



R8-31

R8-31L

R8-31D

R8-31R

GENERAL NOTE:

- SIGNS TO BE SPACED 50' APART OR LESS SO THAT THE TOP OF THE SIGN IS NO LESS THAN 4 FEET AND NO GREATER THAN 6 FEET ABOVE THE FINAL GRADE.



NOTES:

TYPE 1:

- CURBS SHALL BE IDENTIFIED BY A 6 INCH RED PAINT STRIPE ON THE TOP AND SIDE.
- ROLLED CURBS SHALL BE IDENTIFIED BY A 6 INCH RED PAINT STRIPE ON THE UPPER MOST PORTION OF THE CURB.
- ROADS WITH NO CURBS SHALL BE IDENTIFIED BY A 6 INCH RED STRIPE.
- THE WORDS "NO PARKING - FIRE LANE" SHALL BE 18 INCHES HIGH WHITE LETTERING WITH 3 INCH STROKE AND PLACED 8 INCHES AS MEASURED PERPENDICULAR TO THE RED STRIPE. IN MOST CASES, BOTH SIDES SHALL BE MARKED. WHERE LONG ROADS EXIST THE MARKING MAY ALTERNATE SIDES. MARKINGS WILL NOT EXCEED 50' APART.

TYPE 2:

- IN ADDITION TO TYPE 1, HIGHWAY GRADE METAL (ALUMINUM) SIGNS SHALL BE LOCATED AT INTERVALS OR LOCATIONS AS DETERMINED BY THE FIRE CODE OFFICIAL. SIGNS SHALL BE 12" X 18" 3M WHITE HIP PRISMATIC WITH RED 3M ELECTROCRUT FILM LETTERS. POSTS SHALL BE PER 6-82 AND 6-83. THE BOTTOM OF THE SIGN SHALL BE A MINIMUM OF 7 FEET ABOVE THE CURB. SIGNS SHALL BE INSTALLED NOMINALLY PARALLEL TO THE ROAD, FACING THE DIRECTION OF TRAVEL. SIGNS WILL NOT EXCEED 150' APART.
- WHERE SIGNS ARE ADJACENT TO BUILDINGS, THE FIRE CODE OFFICIAL MAY ALLOW THEM TO BE PLACED ON THE BUILDING OR STRUCTURE.
- SEE STANDARD PLAN 6-83 FOR SIGN MOUNTING.

TYPE 3:

- DIAGONAL RED STRIPING ACROSS THE WIDTH OF THE FIRE LANE SHALL BE USED WHEN REQUIRED BY THE FIRE CODE OFFICIAL. IT SHALL BE USED IN CONJUNCTION WITH A 6 INCH RED STRIPE SIMILAR TO TYPE 1. THE STRIPES SHALL RUN AT A 30 TO 60 DEGREE ANGLE AND SHALL BE PARALLEL WITH EACH OTHER. THE STRIPE SHALL BE A MINIMUM 6 INCHES IN WIDTH AND A MINIMUM OF 24 INCHES APART. LETTERING TO OCCUR AS WITH TYPE 1 MARKING.

NOTE: THIS PLAN IS NOT A LEGAL ENGINEERING DOCUMENT BUT AN ELECTRONIC DUPLICATE. THE ORIGINAL, SIGNED BY THE ENGINEER AND APPROVED FOR PUBLICATION IS KEPT ON FILE AT THE CITY OF KENT. A COPY MAY BE OBTAINED UPON REQUEST.

		CITY OF KENT ENGINEERING DEPARTMENT	
		PRIVATE STREET FIRE LANE MARKINGS	
DESIGNED: COK	SCALE: NONE	STANDARD PLAN	
DRAWN: COK	DATE: 2/2020	6-77	
CHECKED: COK	ENGINEER		
APPROVED:			